

**Tate Access Floors, Inc.**  
**Aisle Containment Extension Walls**

**SECTION 09 69 00**  
**Access Flooring Accessories**

- A. Aisle Containment Extension Wall shall be of a fixed variety
- B. Aisle Containment Extension Wall frame shall be manufactured of aluminum
  - a. Shall be anodized
    - i. Shall be available in a clear anodized finish or a black anodized finish
  - b. Shall have a tensile strength of at least 22,000 PSI
- C. Aisle containment Extension Wall shall be fully supported at the base of the Extension Wall
  - a. Shall have the ability to attach to the equipment racks or other aisle containment components for stability
- D. Aisle containment Extension Wall shall have a translucent viewing panel that occupies greater than 75% of the Extension Wall opening
  - a. Translucent panel shall consist of a rigid material consisting of LuciteLux acrylic meeting the following testing criteria
    - i. Must meet UBC Standard 41-2 Class CC-2
    - ii. ASTM E-84 Listed
    - iii. UL 94 Listed
- E. Aisle containment Extension Wall shall have a height of 80” and a width of XX and a depth of no greater than 4.5”