

Tate Access Floors, Inc.

Aisle Containment Doors

SECTION 09 69 00

Access Flooring Accessories

- A. Aisle Containment Door shall be of a swinging or hinged variety
 - a. Shall be left or right hand hinged as required
- B. Aisle Containment door frame shall be manufactured of aluminum
 - a. Shall be anodized
 - b. Shall have a tensile strength of at least 22,000 PSI
- C. Aisle containment door shall be fully supported at the base of the door
 - a. Shall have the ability to attach to the equipment racks or other aisle containment components for stability
- D. Aisle containment door shall have a translucent viewing panel that occupies greater than 75% of the door opening
 - a. Translucent panel shall consist of a rigid material consisting of LuciteLux acrylic meeting the following testing criteria
 - i. Must meet UBC Standard 41-2 Class CC-2
 - ii. ASTM E-84 Listed
 - iii. UL 94 Listed
- E. Aisle containment door shall have a height of XX and a width of XX and a depth of no greater than 4.5"