

Tate Access Floors, Inc.

Retracting Containment Roof

SECTION 09 69 00

Access Flooring Accessories

- A. Retractable Roof shall be capable of use in hot or cold aisle
 - a. Shall not interfere with equipment rack door opening
 - b. Shall be supported by equipment rack requiring no external supports
- B. Retractable Roof shall be equipped with fire suppression link to allow roof to retract in the case of high temperature or fire
 - a. Link shall be approved by UL and FM Global
 - b. Link shall have a supportable load of 45lbs.
 - c. Link shall be of a corrosion resistant construction
 - d. Link shall be a high strength, symmetrical shape, having a solid eye-to-eye connection
- C. Roof material shall be approved by the following standards
 - a. CPAI-84
 - b. NFPA 701
 - c. 1000 hour U.V. ASTM Weatherometer
- D. Retractable roof shall have a minimum width of 60” or 84” where required.
- E. Retractable roof must be configurable to up to 30 feet in length