

# 1 OR 2 HOUR FIRE BARRIER

Tate Access Floors, Inc.  
7510 Montevideo Road  
Jessup, MD 20794  
Tel (410) 799-4200  
Fax (410) 799-4207



Following are Gun-grade sealants which have been used for air plenum sealing and comply with the VDC content limits of LEED EQ Credit 4.1 Low Emitting Materials: Adhesive and Sealants. Deep penetrations must be controlled by the use of back-up filler material; see sealant manufacturer's recommendations for these requirements.

Seal Bond 93 Seam and Penetration Sealant.  
VDC Content: 17g/L. [www.seal-bond.com](http://www.seal-bond.com)

SDNDLASTIC® NP 1 Elastomeric Polyurethane Sealant.  
VDC Content: 43g/L. [www.BuildingSystems.BASF.com](http://www.BuildingSystems.BASF.com)

Pecora AC-20 Acrylic Latex Sealant.  
VDC Content: 31 g/L. [www.pecora.com](http://www.pecora.com)

RCD Corp. #20 Clear Acrylic Adhesive Sealant.  
VDC Content: 110 g/L. [www.rcdplastics.com](http://www.rcdplastics.com)

CONSTRUCT SO THAT FIRE BARRIER CAN  
BE REMOVED AND UNCUT SOLID PANEL  
CAN REPLACE CUT PANELS

