



## PEDESTAL SPECIFICATIONS

### Pedestal Assembly

- Assembly for 100mm FFH shall provide a 2721 kg axial load without permanent deformation.
- Assembly shall provide  $\pm 9\text{mm}$  total adjustment with a minimum finished floor height of 90mm.

### Pedestal Head

- 2mm thick die formed hot dipped galvanized steel pedestal head projection welded to threaded rod
- Electro galvanized solid steel stud shall be 3/4" - 10 UNC and projection welded to base plate.
- Pedestal head shall have tapped holes for engagement of Posilock fasteners.
- Posilock fastener shall be 1/4" - 20 flat-head machine screw.

### Pedestal Base

- Base to be at least 100mm square and hot dipped galvanized steel.
- 38mm electro galvanized coupling nut shall be 3/4" - 10 UNC and projection welded to base.

### Perimeter

- Perimeter pedestal shall provide support for panels around columns and walls.
- Base to be at least 100mm square and hot dipped galvanized steel.
- 28mm electro galvanized coupling nut shall be 3/4" - 10 UNC and projection welded to base.

