

**Tate Access Floors, Inc.**  
**Velocity adjusting devices**

**SECTION 09 69 00**  
**Access Flooring Accessories**

- A. The velocity adjusting device shall consist of a solid sheet of fire resistant material
  - a. Velocity adjusting device shall be made of Sandel material
- B. Velocity adjusting device shall be installable without tools. The velocity adjusting device shall have a tensile strength of 175 lbs/in. The velocity adjusting device shall be available in heights of 6", 12", 18", and 24", and widths shall be available in widths of 24"