



PEDESTAL SPECIFICATIONS

Pedestal Assembly

- Assembly up to 24" FFH shall provide an 8,000 lb. axial load without permanent deformation.
- Assembly shall provide a 2" total adjustment.

Pedestal Head

- .114" thick die formed galvanized steel pedestal head projection welded to a threaded rod with adjustment nut.
- Pedestal head shall have tapped holes for engagement of PosiLock screws and shall incorporate alignment guides and locating points to laterally contain and positively position the floor panel with or without the use of screws.
- Solid steel stud shall be 3/4-10 UNC.
- Galvanized nut shall be 3/4-10 UNC
- PosiLock fastener shall be self capturing 1/4" - 20 flat-head machine screw.
- Stud shall provide an anti-rotation feature when engaged with the pedestal base assembly.

Pedestal Base

- Pedestal tube to be 1-1/8" diameter hot dipped galvanized tubing and shall be reduced to 3/4" inner diameter by swaging or crimping.
- Base plate to be 16 square inch hot dipped galvanized steel and shall have (2) 7/16" diameter holes and (2) 3/16" diameter holes for mechanical fastening applications.