



February 18, 2013

**Subject: Seal Bond 95 Pedestal Adhesive -- LEED-NC V3.0 Credit Compliance**

**Referenced Credit: EQ Credit 4.1: Low-Emitting Materials**

To Whom It May Concern:

Tate Access Floors, Inc. declares that the VOC levels in Seal Bond 95 pedestal adhesive do not exceed the current VOC limits of South Coast Air Quality Management District Rule #1168.

The EQ Credit 4.1 requirement states that all adhesives and sealants used on the interior of the building shall comply with the requirements of South Coast Air Quality Management District Rule #1168.

SCAQMD Rule#1168 specifies a volatile organic compound (VOC) limit of 70 grams per liter for Multipurpose Construction Adhesives. The VOC level of Seal Bond 95 is less than 17g/L.

**Tate Access Floors Technical Services Dept.**

A member of



**Tate Access Floors, Inc.**  
7510 Montevideo Road  
Jessup, MD 20794

Tel: 410-799-4200  
Fax: 410-799-4207

[www.tateaccessfloors.com](http://www.tateaccessfloors.com)